



PUBLIC HEALTH DIVISION  
Drinking Water Services

Kate Brown, Governor

Oregon  
**Health**  
Authority

800 NE Oregon Street, #640  
Portland, OR 97232-2162  
Phone: 971-201-9794  
Fax: 971-673-0694  
[www.healthoregon.org/dwp](http://www.healthoregon.org/dwp)

May 27, 2022

David Karr, PE, PLS  
Project Coordinator  
City of Monmouth  
Via email [dkarr@ci.monmouth.or.us](mailto:dkarr@ci.monmouth.or.us)

**Re: Gwinn Street Waterlines (PR#63-2022)  
City of Monmouth (PWS ID#00537)  
Conditional Approval**

Dear David:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Gwinn Street waterline project for City of Monmouth. On April 13, 2022, our office received a plan review fee of \$3,300. On April 18, 2022, our office received a set of plans.

The project includes installation of 16" C905 PVC waterline and associated appurtenances along Gwinn Street East.

The plans are approved with the following conditions:

- The design must allow for 20 psi to be maintained at all service meters.
- Non-conductive water lines must be provided with a tracer wire. The distance between tracer wire lead access locations must not be more than 1,000 feet.
- Air-relief valves, if needed, must be installed at high points where air can accumulate. The breather tube on air-relief valves must be extended above ground surface and provided with a screened, downward facing elbow.
- Disinfection of the waterline must be completed according to AWWA C651. Results from the coliform sampling must be provided to our office.

**Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use.** Upon completion of the project, the

engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #63-2022 and can be emailed to me at [Carrie.L.Gentry@dhsosha.state.or.us](mailto:Carrie.L.Gentry@dhsosha.state.or.us).

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read 'C. Gentry', written in a cursive style.

Carrie Gentry, PE  
Regional Engineer  
Drinking Water Services

cc: Michelle Byrd, REHS, OHA/DWS  
Matt Johnson, [mjohnson@ci.monmouth.or.us](mailto:mjohnson@ci.monmouth.or.us)