

March 31, 2025

Chuck Scholz ([cscholz@ci.harrisburg.or.us](mailto:cscholz@ci.harrisburg.or.us))  
City of Monroe

Sent by email only

Re: Membrane Module Replacement with Evoqua S10N Modules – PR#[167-2022](#)  
City of Monroe – PWS # [00540](#)  
Final Approval

Dear Chuck:

On March 21, 2025, our office received confirmation that the above project was completed according to the plans submitted and conditions set forth in the December 8, 2022, conditional approval.

This verification completes the plan review requirements. Final approval is issued at this time, and the facility is approved for use. If you have any questions, please feel free to call me at 503-939-1322 or email me at [keith.male@oha.oregon.gov](mailto:keith.male@oha.oregon.gov).

In summary:


Minimum DIT ending pressure: 11.4 psi

PDR<sub>Max</sub> during a DIT: [0.95 psi /min](#)

Log removal credit (LRC): 4.0

Ambient Log Removal Value: displayed & recordable

Sincerely,



Keith Male, PE  
Regional Engineer  
Drinking Water Services

cc: Julie Wray, DWS  
Shawn Stevenson, OHA/DWS