



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-673-0405
Fax: 971-673-0694
www.healthoregon.org/dws

28 April 2025

Allen Dahlberg
City of Mount Angel
P. O. Box 960
Mt. Angel, OR 97362

sent via email only

Re: **Master Plan (PR# 41-2025)**
City of Mount Angel (WS ID# [00544](#))
Concurrence with Master Plan

Dear Mr. Dahlberg:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the water system master plan for the City of Mount Angel. On 1 April 2025, our office received a copy of the Water Master Plan. A plan review fee of \$4,125 was also received.

The Master Plan represents a 20-year planning horizon out to the year 2044. The plan includes a system goals and description, future demand estimates, engineering evaluation, evaluations of options to meet future demand, financing, and a list of recommended projects and cost estimates. A seismic risk assessment and mitigation plan is required and was included. Upon review of the Master Plan, it appears the elements listed in Oregon Administrative Rules (OAR) 333-061-[0060\(5\)](#) have been addressed.

Please note that OAR 333-061-[0060](#) contains plan submission and review requirements for all major water system additions or modifications. Construction plans and specifications must be submitted to and approved by DWS before construction begins.

If you have any questions, please feel free to call me at (971) 201-6428.

Sincerely,

Pete Farrelly, PE
Regional Engineer
Drinking Water Services

cc: Devin Smith, EIT, Civil West Engineering Services, Inc.
Chantal Wikstrom, REHS, OHA-DWS

