

October 16, 2025

Edmund Tawiah
TCC Associates
5821 SE 82nd Ave, Suite 111
Portland, OR 97266

**Re: Mulino Meadows Waterlines (PR#134-2025)
Mulino Water District (PWS ID#00547)
Conditional Approval**

Dear Edmund:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Mulino Meadows Waterlines for Mulino Water District. On October 15, 2025, our office received a set of plans, a land use compatibility statement and a plan review fee of \$825.

The project includes the installation of a ductile iron waterline along Louis Lane in a new development in Mulino, OR.


The plans are approved subject to the following conditions:

- Air-relief valves, if needed, must be installed at high points where air can accumulate. The breather tube on air-relief valves must be extended above ground surface and provided with a screened, downward facing elbow.
- All items in contact with potable water must meet NSF Standard 61.
- The design must allow for 20 psi to be maintained at all service meters.
- Disinfection of the waterline must be completed according to AWWA C651.

Until we receive verification that the conditions have been met and final approval has been issued, the waterline is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #134-2025 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to email me at keith.male@oha.oregon.gov or call me at 503-939-1322.

Sincerely,



Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
Joel Ferguson, REHS, Clackamas County Health Department
Ben Blessing, Planning & Environmental Consulting
Marvin Yogi Trogon, Mulino Water District