

Tina Kotek, Governor

November 4, 2024

Lonnie Rainville  
City of Myrtle Creek  
P.O. Box 940  
Myrtle Creek, OR 97457

*Sent by email only*

Re: **Master Plan Approval (PR#149-2023)**  
**City of Myrtle Creek (PWS ID#00550)**

Dear Lonnie Rainville:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Water System Master Plan for the City of Myrtle Creek. On November 27, 2023, our office received a copy of the Master Plan. A plan review fee of \$3,300 was also received.

The Master Plan represents a 20-year planning horizon out to the year 2043. The plan includes system goals and description, future demand estimates, engineering evaluation, evaluations of options to meet future demand, financing, and list of recommended projects and cost estimates. A seismic risk assessment and mitigation plan was included. Upon review of the Master Plan, it appears the elements required in Oregon Administrative Rules (OAR) 333-061-0060(5) have been addressed.

Please note that OAR 333-061-0060 contains plan submission and review requirements for all major water system additions or modifications. Construction plans and specifications must be submitted to and approved by DWS before construction begins.

If you have any questions, please feel free to call me at 541-650-4868.

Sincerely,



Rebecca Templin, PE, Regional Engineer  
OHA-Drinking Water Services  
[Rebecca.A.Templin@oha.oregon.gov](mailto:Rebecca.A.Templin@oha.oregon.gov)

cc: The Dyer Partnership Engineers & Planners, Inc.

