



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, Suite 640
Portland, OR 97232-2162
Phone: 971-673-0405
Fax: 971-673-0694
www.healthoregon.org/dws

February 14, 2024

Andrew Nishihara, PE
(andrew.nishihara@stantec.com)
Stantec Consulting Services
601 SW 2nd Avenue, 14th floor
Portland, OR 97204

Sent by email only.

Re: **Master Plan – PR# 15-2024**
North Clackamas County Water Commission – WS ID# 00580
Concurrence with Master Plan

Dear Andrew:


Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the water system master plan for the North Clackamas County Water Commission. On January 31, 2024, our office received a copy of the NCCWC Water Treatment Plant Master Plan. A plan review fee of \$4,125 was also received.

The Master Plan represents a 20-year planning horizon out to the year 2043. The plan includes system goals and description, future demand estimates, engineering evaluation, evaluations of options to meet future demand, financing, and a list of recommended projects and cost estimates. A seismic risk assessment and mitigation plan is required and was included. Upon review of the Master Plan, it appears the elements required in Oregon Administrative Rules (OAR) 333-061-[0060\(5\)](#) have been addressed.

Please note that OAR 333-061-[0060](#) contains plan submission and review requirements for all major water system additions or modifications. Construction plans and specifications must be submitted to and approved by DWS before construction begins.

If you have any questions, please feel free to call me at (503) 939-1322 or email me at keith.male@oha.oregon.gov.

Sincerely,

A handwritten signature in black ink that reads "Keith Male". The signature is written in a cursive, flowing style.

Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
Tim Janssen, District Engineer, NCCWC