

September 22, 2025

Thomas L. Amberg, PE
Tech. Engineering
PO Box 80483
Portland, OR 97280

**Re: Odyssey Hills Waterlines (PR#121-2025)
Sunrise Water Authority (PWS ID#00635)
Conditional Approval**

Dear Thomas:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Odyssey Hills Waterlines for Sunrise Water Authority. On September 18, 2025, our office received a Notice of Decision for Type II Land Use, water plans, and a plan review fee of \$3,300.

The project includes the installation of AWWA C151 ductile iron waterlines in the Odyssey Hills proposed residential development.

The plans are approved subject to the following conditions:

- The design must allow for 20 psi to be maintained at all service meters

Until we receive verification that the conditions have been met and final approval has been issued, the waterlines are not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #121-2025 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to email me at keith.male@oha.oregon.gov or call me at 503-939-1322.

Sincerely,



Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
Jeff Baltzell, Sunrise Water Authority
Tim Jannsen, Sunrise Water Authority

