

August 4, 2025

Keith Whisenhunt
Project Delivery Group
7938 Crosby Road NE
Woodburn, OR 97071

**Re: HV 172 Improvements - Waterlines (PR#99-2025)
Sunrise Water Authority (PWS ID#00635)
Conditional Approval**

Dear Keith:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the HV 172 Improvements for Sunrise Water Authority. On August 1, 2025, our office received a land use compatibility statement, a plan review fee of \$3,300, and on August 4, 2025, a set of plans.

The project includes the installation of AWWA C151 ductile iron waterlines connecting new business development to the existing water main in Happy Valley.

The plans are approved subject to the following conditions:

- The design must allow for 20 psi to be maintained at all service meters.
- Disinfection of the waterline must be completed according to AWWA C651, including two samples collected at least 16 hours apart or as noted in the method.

Until we receive verification that the conditions have been met and final approval has been issued, the waterlines are not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #99-2025 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to call me at 503-939-1322 or email me at keith.male@oha.oregon.gov.

Sincerely,



Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
Jeff Baltzell, Sunrise Water Authority
Tim Jannsen, Sunrise Water Authority