

September 25, 2012

Dan Foultnier, Water Plant Operator
City of Rainier
P.O. Box 100
Rainier, OR 97048

800 NE Oregon Street, Suite 640
Portland, OR 97232-2162
Phone: (971) 673-0459
Fax: (971) 673-0694
www.healthoregon.org/dwp

**Re: 15,000 Gallon Storage Reservoir, Plan Review # 138-2012
City of Rainier, PWS ID # 00689
Conditional Approval**


Mr. Foultnier:

Thank you for the submittal of plan review information to Drinking Water Services (DWS) for Rainier's 15,000 gallon storage reservoir. The DWS received a copy of plans and specifications prepared by Jonathan Smith, P.E. of Cascade Water Works, Inc., a geotechnical evaluation of the site, photos, documentation of approval by Columbia County Land Development Services, and a plan review fee of \$600. The project consists of a 15,000 gallon steel storage reservoir at the same location, and replacing the existing redwood reservoir. **The DWS understands that the 15,000 gallon reservoir is currently in service. The project is approved with the following condition:**

1. A silt stop must be provided on the reservoir outlet pipe, as per OAR 333-061-0050 (6)(a)(N).

The engineer must provide written verification to the DWS that the condition of this approval have been met. If there are substantial changes to the project from the plans submitted previously, a set of as-built drawings must be forwarded to the DWS. If you have any questions, or would like this letter in an alternate format, please contact me at either (971) 673-0459 or james.b.nusrala@state.or.us. Thank you for your cooperation.

Sincerely,



James Nusrala, P.E. Regional Engineer

cc: Scott Shulda, Chief Plant Operator, City of Clatskanie, P.O. Box 9, Clatskanie, OR 97016