



800 NE Oregon Street, Suite #640  
Portland, OR 97232-2162  
(971) 673-0459  
(971) 673-0694 – FAX  
<http://healthoregon.org/dwp>

March 9, 2018

Brady Berry, P.E.  
David Evans & Associates, Inc.  
2100 Southwest River Parkway  
Portland, OR 97201

**Re: Rainier Plaza Waterlines, Plan Review # 34-2018  
City of Rainier, PWS ID # 41 00689  
Conditional Approval**

Dear Mr. Berry:

Thank you for your submittal of plan review information for the Rainier Plaza waterline project for the City of Rainier to the Oregon Health Authority's Drinking Water Services (DWS). On March 5, 2018, our office received plans and specifications for the waterline, a land use compatibility statement approved by the City of Rainier, and a plan review fee of \$3,300. On March 8, DWS received follow up clarification on several project details in your email correspondence.

The project includes approximately 700 feet of 8-inch C900 PVC piping to replace an existing 2-inch waterline that serves several properties, to provide expanded fire protection, and serve parking lot landscape irrigation.

**I have reviewed the plans, specifications, and follow up information according to state construction standards. The plans are approved with the following conditions and you may proceed with construction:**

1. Easements for all sections of the waterline on private property must be recorded with Columbia County.
2. Disinfection, flushing, and follow-up coliform sampling for the new waterlines shall be conducted according to American Water Works Association (AWWA) Standard C652.

**Until we receive verification that the project was completed with the conditions listed above and we have granted Final Approval for the project, the waterline is not approved for use.**


Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans and conditions listed above. If substantial

changes are made, a set of record (as-built) drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #34-2018 and can be e-mailed to me at [james.b.nusrala@state.or.us](mailto:james.b.nusrala@state.or.us) or mailed to:

Attn: James Nusrala  
OHA- Drinking Water Services  
800 NE Oregon Street, Suite 640  
Portland, OR 97232-0694

If you have any questions or concerns, or would like this in an alternate format, please contact me at (971) 673-0459, or [james.b.nusrala@state.or.us](mailto:james.b.nusrala@state.or.us). Your cooperation is appreciated.

Sincerely,



James Nusrala, P.E.  
Regional Engineer  
Drinking Water Services

cc:

Debbie Dudley, City Administrator, City of Rainier, 106 West B Street, Rainier, OR 97048