

PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

John A. Kitzhaber, MD, Governor

July 24, 2014

Dan Foultnr, Water Plant Operator
City of Rainier
P.O. Box 100
Rainier, OR 97048

Oregon
Health
Authority

800 NE Oregon Street, Suite 640
Portland, OR 97232-2162
Phone: (971) 673-0459
Fax: (971) 673-0694
www.healthoregon.org/dwp

**Re: 15,000 Gallon Storage Reservoir, Plan Review # 138-2012
City of Rainier, PWS ID # 00689
Final Approval**

Mr. Foultnr:

Thank you for verifying on July 23, 2014 that the condition outlined in the September 25, 2012 conditional approval letter for project has been met (silt stop provided on the reservoir outlet pipe) for Rainier's 15,000 gallon storage reservoir. Earlier, Drinking Water Services received a copy of plans and specifications prepared by Jonathan Smith, P.E. of Cascade Water Works, Inc., a geotechnical evaluation of the site, photos, documentation of approval by Columbia County Land Development Services, and a plan review fee of \$600. The project consists of a 15,000 gallon steel storage replacing the redwood reservoir at the same location. **The project is approved without conditions.**

If you have any questions, or would like this letter in an alternate format, please contact me at either (971) 673-0459 or james.b.nusrala@state.or.us. Thank you for your cooperation in completing the project.

Sincerely,



James Nusrala, P.E. Regional Engineer

cc:

Jim Dahlquist, Water Treatment Plant Operator, City of Rainier
Jonathan Smith, P.E., Cascade Water Works, Inc., 3415 Commercial Street, SE #112,
Salem, OR 97302