



800 NE Oregon Street, Suite #640
Portland, OR 97232-2162
(971) 673-0459
(971) 673-0694 – FAX
<http://healthoregon.org/dwp>

March 21, 2019

David Jacob, P.E.
Rhododendron Water Association
P.O. Box 327
Rhododendron, OR 97049

**Re: Water Treatment Plant and Storage Reservoir, Plan Review # 213-2015
Rhododendron Water District, PWS ID # 00702
Final Approval**

Mr. Jacob:

Thank you for your submittal of supplemental plan review information to the Oregon Health Authority's Drinking Water Services (DWS) for the water treatment plant, pump station, and Hofeldt (Woodlands) storage reservoir. On March 21, 2019, DWS received written verification of project completion and that all conditions of the March 31, 2016 conditional approval have been met, including a copy of a Clackamas County-approved land use compatibility statement for the reservoir. On August 10, 2018, DWS received written correspondence addressing the comments on the slow sand filtration treatment plant included in the 2016 letter. The completed project consists of a slow sand filtration treatment plant to be run in parallel to the existing Rosedale cartridge filtration plant, pump station, and the 135,000 gallon finished water concrete reservoir. **The project is granted final approval and you may place the components into use.**

It is understood that the Harmsco cartridge filters proposed in the plans were not part of this completed project, and are not approved for use. Notify DWS upon installation of the Harmsco units, so that final approval and use of the filters may be granted.

If you have any questions or concerns, or would like this in an alternate format, please contact me at (971) 673-0459, or james.b.nusrala@state.or.us. Thank you for your cooperation in completing the project.

Sincerely,

James Nusrala, P.E., Regional Engineer, Drinking Water Services
cc: Steve Graeper, President of the Board, Rhododendron Water Association, P.O. Box 163, Rhododendron, OR 97049