Public Health Division

Center for Health Protection, Drinking Water Services

Tina Kotek, Governor



December 26, 2024

Robert Tilton City of Riddle PO Box 143 Riddle, OR 97469

sent by email only

Re: Twin Oaks Reservoir #2 (PR#161-2024) City of Riddle (PWS ID#00706) Conditional Approval

Dear Robert Tilton:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Twin Oaks Reservoir #2 for City of Riddle. On December 17th, 2024, DWS received specifications, plans, and a plan review fee of \$3,300.

The project includes the replacement of the existing metal Twin Oaks Reservoir with a new 257,168-gallon steel reservoir on a new concrete base. The work will be located on the northeast side of Riddle, Oregon.

The plans are approved subject to the following conditions:

Finished water storage-

• The outlet ends of the drain and overflow must be fitted with angle-flap valves or equivalent protection and shall discharge to a watercourse or storm drain capable of accommodating the flow with a vertical separation between the bottom of the pipe and top of the receiving body or structure. Refer to OAR 333-061-0050(6)(a)(M).

Until we receive verification that the conditions have been met and final approval has been issued, the new Twin Oaks Reservoir is not approved for use. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #161-2024 and can be emailed to me at zachariah.cunningham-golik@oha.oregon.gov.

If you have any questions, please feel free to call me at 541-231-9077.

Sincerely,

Jach Solis

Zach Golik, PE Regional Engineer Drinking Water Services

2080 Laura St., Springfield, OR 97477-2133 Voice: 971-673-0405 | Fax: 541-465-2914 All relay calls accepted | www.healthoregon.org/dws