



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-201-9794
Fax: 971-673-0694
www.healthoregon.org/dwp

January 31, 2024

Anne Boutwell
Project Coordinator
AKS Engineering & Forestry, LLC
Via email: boutwella@aks-eng.com

**Re: Reservoir Improvements (PR#1-2024)
City of St. Paul (PWS ID#00727)
Conditional Approval**

Dear Anne:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the reservoir improvement project for City of St. Paul. On January 2, 2024, our office received plans, specifications, land use compatibility statement, geotechnical report, and a plan review fee of \$825.

The project includes installation of a 500,000-gallon concrete reservoir, pump station, yard piping and associated appurtenances.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- Please clarify if the fire department connection to the reservoir has an appropriate backflow device on the line.
- Coliform bacteria sample result(s) must be submitted after disinfection of the reservoir is complete.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan

Review #1-2024 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read 'Carrie Gentry', written in a cursive style.

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Chantal Wikstrom, REHS, OHA/DWS
Greg DeBlase, REHS, Marion County Health Department
Ben Unger, Public Works Supervisor, bunger@stpaultel.com