

December 10, 2024

Ben Foster(Ben.Foster@consoreng.com)

Consor Engineering

1 SW Columbia St #1700

Portland, OR 97204

Sent by email only.

**Re: Sandy to Portland Water Filtration Transmission System (PR#165-2024)
City of Sandy (PWS ID#00789)
Conditional Approval**

Dear Ben:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Sandy to Portland Water Filtration Transmission System for the City of Sandy. On October 31, 2024, our office received project plans, specifications and, on December 4, 2024, a plan review fee of \$3,300.

The project includes the installation of a 16-inch ductile iron class 52 waterline from Portland Water Bureau's 16-inch waterline near the future Filtration Plant.

The plans are approved subject to the following conditions:

- A Land Use Compatibility Statement signed by Clackamas County must be submitted prior to the project receiving final approval.
- Water pressure in the distribution system must not be below 20 psi.

Until we receive verification that the conditions have been met and final approval has been issued, the transmission line is not approved for use. For waterline projects, note that engineers must inspect/be prepared to sign off before burying lines. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #165-2024 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to call me at 503-939-1322 or email me at keith.male@oha.oregon.gov.

Sincerely,



Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
AJ Thorne, City of Sandy

