

800 NE Oregon Street, Suite #640
Portland, OR 97232-2162
(971) 673-0405

(971) 673-0694 – FAX

(971) 673-0372 – TTY

<http://www.healthoregon.org/dwp>

June 11, 2013

Joseph Lewis, Water Plant
Supervisor
City of Scappoose
34485 East Columbia Avenue
Scappoose, OR 97056

**Re: Miller Road Production Wells (No. 2 and 3), Plan Review # 45-2003
City of Scappoose, PWS ID # 00792
Final Approval**

Dear Mr. Lewis:

Thank you for the submittal of supplemental information to Drinking Water Services (DWS) related to the City's Miller Road Production Wells No. 2 and 3. DWS received the following items as requested in the May 17, 2006 conditional approval for the project:

- Documentation of an Oregon Water Resources Department (OWRD)-approved Water Management and Conservation Plan for Well No. 2, signed November 21, 2012, including the verification of flow meter on the well pump output, during the November 4, 2010 water system survey.
- April 26, 2012 emailed written verification from the City that property within 100 feet of Well No. 2 is controlled by the City and verification during the November 4, 2010 survey that all sanitary setbacks outlined in Oregon Administrative Rules (OAR) 333-061-0050 (2)(a)(E) are met for Well No. 2.
- Map submitted on August 30, 2010 documenting that no surface water body exists within 500 feet of Well No. 2.
- Final Order for Limited License Application LL-1404 for Well No. 3, approved by OWRD on May 9, 2012. It should be noted that the period of use for the limited license for the well is through November 15, 2015, as noted in Condition 1 of the Order.
- Record drawings for Wells No. 2 and 3, received December 28, 2010.

These submittals satisfy the conditions of the May 17, 2006 letter, and the project is approved without conditions.

Earlier DWS received a site plan for the wells, the OWRD well log (COLU 52428 for No. 2 and COLU 52612 for No. 3), and wellhead specifications. The project consists of 194 foot deep well (Miller Road Well #2) and a 201.5 foot deep well (Miller Road Well #3), which are both treated with Greensand filtration and chlorine and fluoride prior to entering the distribution system through a common entry point, along with Miller Road Well #1 (issued final approval on August 18, 2003). The DWS hydrogeologist has reviewed the respective site plans and well logs for both wells and has approved the well construction. The treatment facility for the wells was granted final approval on April 28th, 2011 by DWS.

If you have any questions or concerns, or would like this in an alternate format, please contact me at (971) 673-0459, or james.b.nusrala@state.or.us. Thank you for your cooperation in completing the project.

Sincerely,



James Nusrala, P.E.

Regional Engineer

cc: Cole Beaman, Oregon Water Resources Water Master, District 18, 1400 SW Walnut, Suite 240, Hillsboro, OR 97123