



25 June 2021

Darryl Sykes  
City of Scappoose  
33568 East Columbia Avenue  
Scappoose Oregon 97056

*via email*

Re: **Airpark Well – PR # 7-2019**  
**City of Scappoose – WS # 00792**  
**Conditional Approval**

Dear Mr. Sykes:

Thank you for your submittal from MurraySmith to the Oregon Health Authority's Drinking Water Services (DWS) of plan for the recently drilled well at the Airpark Development LLC for the City of Scappoose (City). On 5 February 2021, our office received drawings and specifications for the drilled well. On 11 June 2021 our office received an OWRD approved well report.

**The plans are approved with the following conditions** {unless otherwise noted, rule references are from [OAR 333-061-0050...](#) }:

- If site is prone to flooding well casing (& reservoir) must be raised. (2)(a)(F)
- Assure the depth of the static/pumped water in the well is measurable. (2)(a)(K)(iv)
- All items in contact with potable water must meet NSF Standard 61. [333-061-0087\(5\)](#)
- Confirmation of agency coordination with WRD on well report details.

**Until we receive verification that the conditions have been met and final approval has been issued, the project is not approved for use.** Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #7-2019 and can be emailed to me at the address above or mailed to:

Attn: [Pete Farrelly](#)  
OHA-Oregon Drinking Water Services  
PO Box 14450  
Portland, OR 97293-0450

If you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Pete Farrelly". The signature is written in a cursive style and is placed on a light blue rectangular background.

Pete Farrelly, PE  
Regional Engineer  
Drinking Water Services

ec: Michael McKillip, MurraySmith  
888 SW 5<sup>th</sup> Avenue, Suite 1170  
Portland, OR 97204