



PUBLIC HEALTH DIVISION
Drinking Water Services

Kate Brown, Governor

Oregon
Health
Authority

2080 Laura Street
Springfield, OR 97477
Phone: 971-673-0405
Fax: 541-465-2914
www.healthoregon.org/DWP

10 August 2022

Todd Thompson
President, Shangri-La WD
88059 Keola Lane
Springfield, OR 97478

**Re: Additional Filter Train (PR#2022-123)
Shangri-La Water District (PWS ID#OR4100835)
Conditional Approval**

Dear Jamie:

Thank you for sending plans to the Oregon Health Authority's Drinking Water Services (DWS) for the referenced project designed by Branch Engineering for Shangri-La WD. The plan review fee of \$825 was paid 3 August 2022 and design documents received 9 August 2022. DWS grants the project conditional approval.

The project involves installing a parallel filter train identical to the existing filter train (Harmsco Muni 1-2FL-304 housing and HC/170-LT2 filter). Should the as-built conditions deviate from plans significantly, please provide drawings. If you have any questions, please feel free to email me at james.r.macpherson@dhsosha.state.or.us or dws.planreview@dhsosha.state.or.us or call me at (541) 231-0762.

Sincerely,

Jay MacPherson, PE
Plan Review Coordinator
Drinking Water Services

ec: DWS Portland
Jamie Porter, Rainbow Water District
Lane County Environmental Health