

June 23, 2023



800 NE Oregon Street, #640 Portland, OR 97232-2162 Phone: 971-201-9794 Fax: 971-673-0694 www.healthoregon.org/dwp

Brooke Shattuck 4B Engineering & Consulting, LLC Via email: brooke.4b@outlook.com

Re: Hobson Reservoir #2 (PR#59-2023) City of Sublimity (PWS ID#00844) Conditional Approval

Dear Brooke:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Hobson Reservoir 2 project for City of Sublimity. On April 24, 2023, our office received plans, specifications and a land use compatibility statement. A plan review fee of \$3,300 was received on April 25, 2023. Amended plans were submitted on May 10, 2023.

The project includes installation of a 750,000-gallon steel reservoir and associated piping and appurtenances.

The plans are approved with the following conditions:

- The outlet end of the drain/overflow must be fitted with angle-flap valve or equivalent protection and must discharge with an airgap to a watercourse or storm drain capable of accommodating the flow.
- Coliform bacteria sample result(s) must be submitted after disinfection of the reservoir is complete.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan

Review #59-2023 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794. Sincerely,

CAY

Carrie Gentry, PE Regional Engineer Drinking Water Services

ec: Chantal Wikstrom, REHS, OHA/DWS Greg DeBlase, REHS, Marion County Health Department Alan Frost, Public Works Director, City of Sublimity, alan.frost@cityofsublimity.org