



September 11, 2023

Paige N. VanLaanen
AKS Engineering & Forestry, LLC
Via email: vanlaanenp@aks-eng.com

**Re: Heather Meadows Waterline Project (PR#114-2023)
City of Sublimity (PWS ID#00844)
Conditional Approval**

Dear Paige:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Heather Meadows waterline project in the City of Sublimity. On August 23, 2023, our office received plans, land use compatibility statement and a plan review fee of \$3,300.

The project includes installation of C900 PVC waterline and associated appurtenances to serve the new Heather Meadows development in the City.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- The design must allow for 20 psi to be maintained at all service meters.
- The distance between tracer wire lead access locations must not be more than 1,000 feet.
- After disinfection of the waterlines is completed, results from the coliform sampling must be provided to our office.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan

Review #114-2023 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read 'Carrie Gentry', with a stylized flourish at the end.

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Chantal Wikstrom, REHS, OHA/DWS
Greg DeBlase, REHS, Marion County Health Department
Alan Frost, Public Works Director, City of Sublimity
Andy Medcalf, andy@andymedcalfconstruction.com