



PUBLIC HEALTH DIVISION  
Drinking Water Services

Tina Kotek, Governor

Oregon  
**Health**  
Authority

800 NE Oregon Street, #640  
Portland, OR 97232-2162  
Phone: 971-201-9794  
Fax: 971-673-0694  
[www.healthoregon.org/dwp](http://www.healthoregon.org/dwp)

October 24, 2023

Cem. E. Gokcora, PE  
Senior Engineer  
Maul Foster & Alongi, Inc.  
Via email: [cgokcora@maulfoster.com](mailto:cgokcora@maulfoster.com)

**Re: Riverside Pump Station (PR#125-2023)  
City of The Dalles (PWS ID#00869)  
Conditional Approval**

Dear Cem:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Riverside Pump Station project for City of The Dalles. On September 12, 2023, our office received a submittal that included plans and specifications. A plan review fee of \$3,300 was received on September 20, 2023.

The project includes installation of a pump station located on the same site as the Riverside Wells and Reservoirs. The pump station will include three 1,800 gpm pumps and one 900 gpm pump, with space for three more 1,800 pumps. One of the spaces can be used for a spare 900 gpm pump as well.

The plans are approved with the following condition:

- All items in contact with potable water must meet NSF Standard 61 or equivalent.

**Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use.** Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #125-2023 and can be emailed to me at [Carrie.L.Gentry@oha.oregon.gov](mailto:Carrie.L.Gentry@oha.oregon.gov).

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read 'C. Gentry', with a stylized flourish at the end.

Carrie Gentry, PE  
Regional Engineer  
Drinking Water Services

cc: Michelle Byrd, REHS, OHA/DWS  
Dave Anderson, Public Works Director, [danderson@ci.the-dalles.or.us](mailto:danderson@ci.the-dalles.or.us)