



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-201-9794
Fax: 971-673-0694
www.healthoregon.org/dwp

July 5, 2023

Michael McKillip, PE, PhD
Senior Engineer
Conсор
Via email: Michael.McKillip@consoreng.com

**Re: Reservoir 18 and Pump Station (PR#65-2023)
City of Tigard (PWS ID#00878)
Conditional Approval**

Dear Mr. McKillip:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Reservoir 18 and Pump Station project for City of Tigard. On June 5, 2023, our office received plans, specifications, land use compatibility statement and geotechnical report. A plan review fee of \$4,125 was received on May 1, 2023.

The project includes installation of a buried 4.5 MG concrete reservoir, a pump station and associated piping and appurtenances to connect the infrastructure to the water system. The pump station will serve two pressure zones.

The plans are approved with the following conditions:

- Coliform bacteria sample results must be submitted after the disinfection of the reservoir and waterlines is complete.
- All items in contact with potable water must meet NSF Standard 61 or equivalent.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #65-2023 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read 'C. Gentry', with a stylized flourish at the end.

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Nicole Alfafara, REHS, OHA/DWS
Shasta Billings-Beck, PE, Senior Project Engineer, City of Tigard, shastab@tigard-or.gov