

September 12, 2011

Richard G. Gitschlag, P.E.
North Coast Engineering Services
1914 Fourth Street
Tillamook, OR 97141

**Re: Plan Review - Rose Lane Road and Water Extension
(PR #153-2011; PWS #00884)
Conditional Approval**

The Oregon Drinking Water Program received your plan review submittal for the referenced project on September 2, 2011, and supplemental information on September 7, 2011. The project involves the construction of approximately 1125 lf of 2" waterline to serve five or six new residential connections. The waterline will be connected to an existing distribution pipeline of the Pleasant Valley Water Company (PWS #00884). At this time, I have completed my review of the project, and grant *conditional approval*.

Condition of Approval

Prior to activating the waterline, documentation must be provided to DWP showing that a perpetual easement has been granted to the Pleasant Valley Water Company for operation and maintenance of the proposed waterline.

Final plan review approval will be granted upon completion of the proposed project, your certification that the project was completed according to the submitted plans and specifications, and receipt by DWP of a copy of the required easement.

If you have any questions, please contact me at (971) 673-0406, or via email at fred.n.kalish@state.or.us.

Richard G. Gitschlag, P.E., Conditional Approval
September 12, 2011
Page 2

Sincerely,

Fred Kalish, P.E.
Regional Engineer
DHS Drinking Water Program

cc: Marsha Fox, DHS Portland
Ken & Nonda Zwald, Pleasant Valley Water Co., 9540 Hurliman Hill
Rd, Tillamook, OR 97141
Annette Pampush, Tillamook County

