

Tina Kotek, Governor

October 7, 2024

Brian Ginter, PE
Conсор
Via email: Brian.Ginter@consoreng.com

Re: **Master Plan Approval (PR#105-2024)**
Pleasant Valley Water Co (PWS ID#00884)

Dear Brian:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the 2024 Water System Master Plan for Pleasant Valley Water Co. On August 27, 2024, our office received a copy of the plan. A plan review fee of \$825 was received on August 14, 2024.

The Master Plan represents a 20-year planning horizon out to the year 2044. The plan includes system goals and description, future demand estimates, engineering evaluation, evaluations of options to meet future demand, financing, and list of recommended projects and cost estimates. A seismic risk assessment and mitigation plan was required and was included. Upon review of the Master Plan, it appears the elements required in Oregon Administrative Rules (OAR) 333-061-0060(5) have been addressed.

Please note that OAR 333-061-0060 contains plan submission and review requirements for all major water system additions or modifications. Construction plans and specifications must be submitted to and approved by DWS before construction begins.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,



Carrie Gentry, PE
Regional Engineer
OHA-Drinking Water Services
Carrie.L.Gentry@oha.oregon.gov

cc: Clyde Wagner, Pleasant Valley Water Co