

Tina Kotek, Governor

April 23, 2026

Taylor Spencer, PE
Professional Engineer
Conсор
Via email: Taylor.Spencer@consoreng.com

**Re: 108th Ave Pump Station (PR#5-2026)
City of Tualatin (PWS ID#00905)
Conditional Approval**

Dear Taylor:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the 108th Ave Pump Station project for City of Tualatin. On March 5, 2026, our office received a set of plans, specifications, and a land use compatibility statement. A plan review fee of \$3,300 was received on January 29, 2026.

The project includes installation of a pump station for the 108th Ave reservoir (reviewed under PR #6-2026).

The plans are approved with the following condition:

- All items in contact with potable water must meet NSF Standard 61 or equivalent.

Until we receive verification that the condition has been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above condition was met should reference Plan Review #5-2026 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,



Carrie Gentry, PE
Regional Engineer
OHA-Drinking Water Services
Carrie.L.Gentry@oha.oregon.gov

cc: Nicole Alfafara, REHS, OHA/DWS
Terrance Leahy, Water Division Manager, City of Tualatin
Abby McFetridge, EI, Engineering Associate, City of Tualatin