

Tina Kotek, Governor

April 23, 2026

Taylor Spencer, PE  
Professional Engineer  
Conсор  
Via email: Taylor.Spencer@consoreng.com

**Re: 108<sup>th</sup> Ave Pump Station (PR#5-2026)  
City of Tualatin (PWS ID#00905)  
Conditional Approval**

Dear Taylor:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the 108<sup>th</sup> Ave Reservoir project for City of Tualatin. On March 5, 2026, our office received a set of plans, specifications, geotechnical report, and a land use compatibility statement. A plan review fee of \$3,300 was received on January 29, 2026.

The project includes installation of a 2.5-million-gallon pre-stressed concrete reservoir.

**The plans are approved with the following conditions:**

- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- Disinfection of the reservoir prior to use must be accomplished according to AWWA Standard C652.

**Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use.** Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #6-2026 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,



Carrie Gentry, PE  
Regional Engineer  
OHA-Drinking Water Services  
[Carrie.L.Gentry@oha.oregon.gov](mailto:Carrie.L.Gentry@oha.oregon.gov)

cc: Nicole Alfafara, REHS, OHA/DWS  
Terrance Leahy, Water Division Manager, City of Tualatin  
Abby McFetridge, EI, Engineering Associate, City of Tualatin