

July 6, 2023



800 NE Oregon Street, #640 Portland, OR 97232-2162 Phone: 971-201-9794 Fax: 971-673-0694 www.healthoregon.org/dwp

Bailey Williams, EIT Staff EIT A & O Engineering, LLC Via email: baileywilliams@ao-engr.com

Re: Oakley Estates Subdivision Phase 1 and 2 (PR#81-2023) City of Veneta (PWS ID#00920) Conditional Approval

Dear Bailey:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Oakley Estates Subdivision Phase 1 and 2 waterline project for City of Veneta. On June 23, 2023, our office received plans and a land use compatibility statement. A plan review fee of \$3,300 was received on June 28, 2023.

The project includes installation of 6" and 8" ductile iron pipe and associated appurtenances for phase 1 and 2 for the Oakley Estates Subdivision.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- The design must allow for 20 psi to be maintained at all service meters.
- Disinfection of the waterline must be completed according to AWWA C651. Results from the coliform sampling must be provided to our office.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #81-2023 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794. Sincerely,

City

Carrie Gentry, PE Regional Engineer Drinking Water Services

cc: Amy Bleekman, REHS, OHA/DWS Kyle Schauer, Public Works Director, City of Veneta, kschauer@ci.veneta.or.us