



PUBLIC HEALTH DIVISION  
Drinking Water Services

Kate Brown, Governor

Oregon  
**Health**  
Authority

800 NE Oregon Street, #640  
Portland, OR 97232-2162  
Phone: 971-673-0191  
Fax: 971-673-0694  
[www.healthoregon.org/DWP](http://www.healthoregon.org/DWP)

July 14, 2017

Erik Hoovestol, PE  
Firwood Design Group, LLC  
359 E. Historic Columbia River Highway  
Troutdale, OR 97060

Re: **Waterfront Trail Landing Subdivision (PR#73-2017)**  
**City of Warrenton (PWS ID#00932)**  
**Conditional Approval**

Dear Mr. Hoovestol:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Waterfront Trail Landing Subdivision for the City of Warrenton water system. On June 16, 2017, our office received a set of plans, land use compatibility statement and a plan review fee of \$3,300.

The project includes installation of C900 PVC pipe and associated appurtenances for the Waterfront Trail Landing Subdivision.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF Standard 61.
- The design must allow for 20 psi to be maintained at all service meters.
- Disinfection of the waterline must be completed according to AWWA C651.
- Any sewer and water line crossings where the waterline crosses under the sewer line must conform to OAR 333-061-0050 (9)(c)(C).

**Until we receive verification that the conditions have been met and final approval has been issued, the project is not approved for use.** Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #73-2017 and can be emailed to me at [Carrie.L.Gentry@state.or.us](mailto:Carrie.L.Gentry@state.or.us) or mailed to:

Attn: Carrie Gentry  
OHA-Oregon Drinking Water Services  
PO Box 14450  
Portland, OR 97293-0450

If you have any questions, please feel free to call me at (971) 673-0191.

Sincerely,

A handwritten signature in black ink, appearing to read 'Carrie Gentry', written in a cursive style.

Carrie Gentry, PE  
Regional Engineer  
Drinking Water Services

cc: Evan Hofeld, PE, OHA/DWS  
Bob Bingham, City of Warrenton  
Ben Johnson, Sunrise Homes