



PUBLIC HEALTH DIVISION
Drinking Water Services

Kate Brown, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-673-0191
Fax: 971-673-0694
www.healthoregon.org/DWP

November 19, 2019

Collin Stelzig, PE, Public Works Director
City of Warrenton
PO Box 250
Warrenton, OR 97146

**Re: Hammond Waterline (PR#170-2019)
City of Warrenton (PWS ID#00932)
Conditional Approval**

Dear Mr. Stelzig:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Hammond waterline project for the City of Warrenton. On November 13, 2019, our office received a set of plans. A plan review fee of \$3,300 was received on November 7, 2019.

The project includes installation of an 18" C905 waterline and associated appurtenances.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF Standard 61.
- The design must allow for 20 psi to be maintained at all service meters.
- The distance between tracer wire lead access locations must not be more than 1,000 feet.
- Results from the post-disinfection coliform sampling must be provided to our office.
- Any sewer and water line crossings must conform to OAR 333-061-0050(9). Parallel separations must also conform to this rule. Note that any zone conflicts represented in Figure 1 in that rule other than zone 1 conflicts must be approved by OHA/DWS.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted

plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #170-2019 and can be emailed to me at Carrie.L.Gentry@state.or.us or mailed to:

Attn: Carrie Gentry
OHA-Oregon Drinking Water Services
PO Box 14450
Portland, OR 97293-0450

If you have any questions, please feel free to call me at (971) 673-0191.

Sincerely,

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

ec: Peter Farrelly, PE, OHA/DWS