



31 July 2020

Curtis Vanderzanden, PE
KPFF Consulting Engineers
111 SW Fifth Avenue, Suite 2600
Portland Oregon 97204

**Re: Waterlines – Bugle Road Watermain Extension (PR#89-2020)
City of Warrenton (WS ID# 00932)
Conditional Approval**

Mr. Vanderzanden:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Bugle Road waterline project in the City Warrenton. On 15 July 2020 our office received plans, specifications, land use compatibility statement, and a plan review fee of \$3,300.

The project includes installation of 658 feet of 12" C900 PVC DR14 & 110 feet of 8" waterline & associated appurtenances in a development area a half-mile east of Highway 101.

The plans are approved with the following condition(s) {unless otherwise noted, rule references are from [OAR 333-061-0050...](#) }:

- Provide tracer wire or other approved conductor for locating the pipe. The distance between tracer lead access locations shall not be more than 1,000 feet. (8)(k)
- Assure all piping is carefully bedded and covered at least 30". (8)(f)
- All items in contact with potable water must meet NSF Standard 61. 333-061-0087(5)

Until we receive verification that the conditions have been met and final approval has been issued, the project is not approved for use. Documentation demonstrating how the above conditions were met should reference Plan Review #89-2020 and can be emailed to me at the address above or mailed to:

Attn: [Pete Farrelly](#)
OHA-Oregon Drinking Water Services
PO Box 14450
Portland, OR 97293-0450

If you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink on a light blue background. The signature is cursive and appears to read "Pete Farrelly".

Pete Farrelly, PE
Regional Engineer
Drinking Water Services

cc: [Collin Stelzig](#), PE, City of Warrenton
[Fred Maddox](#), PE, KPFF Consulting Engineers