

September 16, 2024

Brooke Harrison [Brooke.Harrison@consoreng.com]
Conсор Engineering
One SW Columbia Street, Suite 1700
Portland, Oregon 97204

Sent by email only.

Re: **Master Plan Approval (PR#108-2024)**
City of West Linn (PWS ID#00944)

Dear Brooke:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Water System Master Plan for the City of West Linn. On August 15, 2024, our office received a copy of the Water System Master Plan Update. A plan review fee of \$4,125 was also received on September 5, 2024.

The Master Plan represents a 20-year planning horizon out to the year 2044. The plan includes system goals and description, future demand estimates, engineering evaluation, evaluations of options to meet future demand, financing, and list of recommended projects and cost estimates. A seismic risk assessment and mitigation plan is required and was included. Upon review of the Master Plan, it appears the elements required in Oregon Administrative Rules (OAR) 333-061-0060(5) have been addressed.

Please note that OAR 333-061-0060 contains plan submission and review requirements for all major water system additions or modifications. Construction plans and specifications must be submitted to and approved by DWS before construction begins.

If you have any questions, please feel free to email me at keith.male@oha.oregon.gov or call me at 503-939-1322.

Sincerely,



Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS

- Brian Ginter, PE, Consor: Brian.ginter@consoreng.com
- Matthew Kaatz, City of West Linn: mkaatz@westlinnoregon.gov
- Erich Lais, City of West Linn: elais@westlinnoregon.gov