



PUBLIC HEALTH DIVISION
Drinking Water Services

Kate Brown, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-673-0191
Fax: 971-673-0694
www.healthoregon.org/DWP

March 24, 2016

Corbey Boatwright, PE
Boatwright Engineering, Inc.
2613 12th Street SE
Salem, OR 97302

Re: **Coyote Point Subdivision waterlines (PR#33-2016)**
Westport Water Association (PWS ID#00950)
Conditional Approval

Dear Mr. Boatwright:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Coyote Point Subdivision project for Westport Water Association. On March 10, 2016, our office received a set of plans, land use compatibility statement, preliminary subdivision plat map and a plan review fee of \$825.

The project includes installation of 6" PVC waterlines in a new subdivision along with the associated appurtenances.

The plans are approved with the following conditions:

- If no public easement exists for the waterline, a copy of the new easement must be provided to our office. The easement must also be recorded with the county clerk.
- The design must allow for 20 psi to be maintained at all service meters.
- The distance between tracer lead access locations must not be more than 1,000 feet.
- Any sewer and water line crossings must conform to OAR 333-061-0050(9). Parallel separations must also conform to this rule.

Until we receive verification that the conditions have been met and final approval has been issued, the project is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted

plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #33-2016 and can be emailed to me at Carrie.L.Gentry@state.or.us or mailed to:

Attn: Carrie Gentry
OHA-Oregon Drinking Water Services
PO Box 14450
Portland, OR 97293-0450

If you have any questions, please feel free to call me at (971) 673-0191 or Evan Hofeld at (971) 673-0419.

Sincerely,

A handwritten signature in black ink, appearing to read 'Carrie Gentry', with a stylized flourish at the end.

Carrie Gentry, PE
Plan Review Coordinator
Drinking Water Services

cc: Evan Hofeld, OHA/DWS
Calvin Shulda, Westport Water Association
Michael McNickle, Clatsop County Health Department