



March 13, 2020

Steven Ward, PE  
Westech Engineering, Inc.  
3841 Fairview Industrial Drive SE, Suite 100  
Salem, OR 97302

**Re: Ridgeview Heights Subdivision (PR#24-2020)  
City of Willamina (PWS ID#00953)  
Conditional Approval**

Dear Mr. Ward:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Ridgeview Heights Subdivision waterline project for City of Willamina. On February 21, 2020, our office received a set of plans, land use compatibility statement and a plan review fee of \$3,300.

The project includes installation of 6" and 8" waterlines and associated appurtenances for the Ridgeview Heights Subdivision project.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- The design must allow for 20 psi to be maintained at all service meters.
- Air-relief valves, if needed, must be installed at high points where air can accumulate. The breather tube on air-relief valves must be extended above ground surface and provided with a screened, downward facing elbow.
- Any sewer and water line crossings must conform to OAR 333-061-0050(9).
- Disinfection of the waterline must be completed according to AWWA C651. Results from the coliform sampling must be provided to our office.

**Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use.** Upon completion of the project, the

engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #24-2020 and can be emailed to me at Carrie.L.Gentry@state.or.us or mailed to:

Attn: Carrie Gentry  
OHA-Oregon Drinking Water Services  
PO Box 14450  
Portland, OR 97293-0450

If you have any questions, please feel free to call me at (971) 673-0191.

Sincerely,



Carrie Gentry, PE  
Regional Engineer  
Drinking Water Services

ec: Pete Farrelly, PE, OHA/DWS

cc: Justin Riggs, City of Willamina  
Tim Wenger, Keystone Builders LLC, 271 N 20<sup>th</sup> Place, Philomath, OR 97370