



May 13, 2024

Adam Blair (adam.blair@consoreng.com)
Consor Engineering
One SW Columbia Street, Suite 1700
Portland, OR 97204

Sent by email only.

Re: West Side Level B Reservoir & Tooze Road Transmission Main (PR#65-2024)
City of Wilsonville – WS # 00954)
Conditional Approval

Dear Adam:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the West Side Level B Reservoir & Tooze Road Transmission Main Project for the City of Wilsonville. On May 1, 2024, our office received a set of plans and a plan review fee of \$4,125.

The project includes the installation of a 3-million-gallon concrete reservoir and a 24" class 52 ductile iron transmission main along Tooze Road. The transmission main is an extension of the distribution system to reach the location of the planned reservoir.

The plans are approved with the following conditions:

- A Land Use Compatibility Statement signed by Clackamas County must be submitted prior to the project receiving final approval.

Storage Reservoir:

- A silt stop must be provided at the outlet pipe.

Distribution:


- The design must allow for 20 psi to be maintained in the distribution system.

Until we receive verification that the conditions have been met and final approval has been issued, the reservoir and distribution main are not approved for use. Upon

completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #65-2024 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to call me at 503-939-1322 or email me at keith.male@oha.oregon.gov.

Sincerely,

A handwritten signature in black ink that reads "Keith Male". The signature is written in a cursive, slightly slanted style.

Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
Delora Kerber, City of Wilsonville