



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-201-9794
Fax: 971-673-0694
www.healthoregon.org/dwp

October 24, 2023

Niall Boggs, PE, CWRE
Senior Engineer
Parametrix
Via email: NBoggs@parametrix.com

**Re: Pinecrest Reservoir (PR#128-2023)
Oregon Water Utilities – Pinecrest (PWS ID#01128)
Conditional Approval**

Dear Niall:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Pinecrest Reservoir project for Oregon Water Utilities - Pinecrest. On September 21, 2023, our office received a set of plans, specifications and land use compatibility statement. A plan review fee of \$825 was received on October 3, 2023.

The project includes installation of an 85,000-gallon bolted steel tank. The tank will be built next to the existing redwood tank, with the intention to replace or decommission the redwood tank in the next few years.

The plans are approved with the following conditions:

- The roof access hatch must have curbing around the opening and a lockable watertight cover that overlaps the curbing.
- Coliform bacteria sample result(s) must be submitted after disinfection of the reservoir is complete.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted.

Documentation demonstrating how the above conditions were met should reference Plan Review #128-2023 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read 'Carrie Gentry', written in a cursive style.

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Russ Kazmierczak, RG, OHA/DWS
David Rico, Parametrix, DRico@parametrix.com
Lance Lindow, REHS, Klamath County Environmental Health