

PUBLIC HEALTH DIVISION
Environmental Public Health Office, Drinking Water Program
John A. Kitzhaber, MD, Governor
September 26, 2011



800 NE Oregon Street, Suite #640
Portland, OR 97232-2162
(971) 673-0405
(971) 673-0694 – FAX
(971) 673-0372 – TTY

Rick Brown-Midland Water Association
15426 Riverfront Road
Clatskanie, OR 97016

**Re: Minor Modifications to Finished Water Reservoir, Plan Review # 156-2011
Midland Water Association, Public Water System ID # 41 01139
Conditional Approval**

Dear Mr. Brown:


Thank you for your submittal of plans for the Minor Modifications to the 42,000 Gallon Finished Water Reservoir at the Midland Water Association. The Drinking Water Program (DWP) received a copy of the plan submittal from Micah Olson, who is copied on this correspondence. A waiver from the plan review fee has been approved, as the project consists of minor modifications to an existing water system facility. The project includes constructing a new steel watertight roof, with a screened vent, and a screened outlet on the overflow pipe. **The project is approved with the following conditions:**

- The curbed roof hatched entry to the reservoir must be lockable, as required by Oregon Administrative Rules (OAR) 333-061-0050 (6)(a)(J).

Upon completion of the project, Midland must verify that construction was completed according to the submitted plans, and that all conditions of the approval listed above have been addressed. If substantial changes are made, a set of 'as-built' drawings must be submitted.

If you have any questions or concerns, or would like this in an alternate format, please contact me at (971) 673-0459, or james.b.nusrala@state.or.us. Your cooperation is appreciated.

Sincerely,


James Nusrala, P.E.

Regional Engineer

<http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater>

cc: Micah Olson; P.O. Box 1776; Redmond, OR 97756

*"Assisting People to Become Independent, Healthy, and Safe"
An Equal Opportunity Employer*