

PUBLIC HEALTH DIVISION  
Environmental Public Health Office, Drinking Water Program  
John A. Kitzhaber, MD, Governor



800 NE Oregon Street, Suite #640  
Portland, OR 97232-2162  
(971) 673-0405  
(971) 673-0694 – FAX  
(971) 673-0372 – TTY  
[www.healthoregon.org/dwp](http://www.healthoregon.org/dwp)

June 18, 2012

Scott MacGregor  
Midland Water Association  
P.O. Box 22  
Clatskanie, OR 97016

**Re: Minor Modifications to Finished Water Reservoir, Plan Review # 156-2011  
Midland Water Association, Public Water System ID # 41 01139  
Final Approval**

Dear Mr. MacGregor:

Thank you for your submittal of information related to the Minor Modifications to the 42,000 Gallon Finished Water Reservoir at the Midland Water Association. The Drinking Water Program (DWP) received written verification that all conditions outlined in the September 26, 2011 conditional approval letter have been met, from Micah Olson, who is copied on this correspondence. The project includes constructing a new steel watertight roof, with a screened vent, a lockable hatch, and a screened outlet on the overflow pipe on the existing reservoir. **The project is approved without conditions.**

If you have any questions or concerns, or would like this in an alternate format, please contact me at (971) 673-0459, or [james.b.nusrala@state.or.us](mailto:james.b.nusrala@state.or.us). Thank you for your cooperation in completing the project.

Sincerely,

A handwritten signature in blue ink that reads "James Nusrala".

James Nusrala, P.E.  
Regional Engineer

cc: Micah Olson; P.O. Box 1776; Redmond, OR 97756