

September 17, 2024

David Jacob
Hydra Engineering
PO Box 327
Rhododendron, OR 97049

**Re: Temporary Storage Replacement (PR#124-2024)
Zig Zag Co-Operative (PWS ID#01241)
Conditional Approval**

Dear David:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Temporary Storage Replacement for Zig Zag Co-Operative. On September 11, 2024, our office received a project description, drawings, and on September 16, 2024, a plan review fee of \$825.


The project includes the installation of a 500 gallon Norwesco HDPE storage tank inside the treatment building just after chlorination.

The plans are approved with the following conditions:

- Coliform bacteria sample result(s) must be submitted after disinfection of the storage tank is complete.

Until we receive verification that the conditions have been met and final approval has been issued, the tank is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #124-2024 and can be emailed to me at keith.male@oha.oregon.gov or call me at 503-939-1322.

Sincerely,



Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
Joel Ferguson, REHS, Clackamas County Health Department