



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, Suite 640
Portland, OR 97232-2162
Phone: 971-673-0405
Fax: 503-673-0694
www.healthoregon.org/dws

12 April 2024

John Gastineau
Young Life
PO Box 220
Antelope, Oregon 97001

[Sent by email only](#)

Re: Membrane modules (4) replacement – PR#[146-2023](#)
Young Life – PWS # [01246](#)
Final Approval

Dear Mr. Gastineau:

On 21 December 2023 our office received confirmation that the above project was completed according to the plans described and the correlating details that are summarized in the related PR 75-2021 Final Approval letter, dated [9 November 2023](#).

This verification completes the plan review requirements. Final approval is issued at this time, and the facility is approved for use. If you have any questions, please feel free to call me at 971.201.6428.

In summary:

Minimum DIT ending pressure: 18.21 psi

PDR_{Max} during a DIT: [0.098](#) ^{psi}/_{min}

Log removal credit (LRC): 4.0

Ambient Log Removal Value: displayed & recordable

Sincerely,

Pete Farrelly, Regional Engineer
OHA-Drinking Water Services

cc: Chantal Wikstrom, OHA-DWS