

May 15, 2025

John McAllister, PE
Jacob Cain, PE
Port of Morrow
PO Box 200
Boardman, Oregon 97818

**Re: Airport Water Lines, Plan Review #80-2024, Port of Morrow, PWS ID #4101328
Preliminary Approval**

Dear John & Jacob:

Thank you for your submittal of plan review information to the Oregon Health Authority's Drinking Water Services (DWS). On June 10, 2024, a Land Use Compatibility Statement was received. On July 16, 2024, our office received a printed copy of the plans for the project. On February 27, 2025, the plan review fee of \$825 was received. The project consists of installing 24-inch diameter HDPE water lines, valves, hydrants, and related appurtenances at the airport site. The plans have been reviewed and preliminary approval is granted for the project.

I have the following comment:

1. I note that movement of the the HDPE pipe and fittings is prevented by the welded flange adapters, eliminating the need for thrust blocks as described in your May 13, 2025 email.

Upon completion of the project, please verify in writing that the construction was completed according to the submitted plans. If substantial changes are made, a set of record (as-built) drawings must be submitted. Until it is verified that the project meets the construction standards in OAR 333-061-0050 and Final Approval is granted for the project, the new facilities are not approved for use.

May 15, 2025

If you have any questions or would like this in an alternate format, please feel free to call me at (541) 966-0900 or email at william.h.goss@oha.oregon.gov .

Sincerely,



William Goss, PE
Regional Engineer

c: Julie Wray, OHA-DWS
Miff Devin, Port of Morrow (pdf copy only)

