

May 16, 2025

Jacob Cain, PE  
John McAllister, PE  
Port of Morrow  
PO Box 200  
Boardman, Oregon 97818

**Re: Gar Swanson Water Lines, Plan Review #30-2025, Port of Morrow,  
PWS ID #4101328  
Conditional Approval**

Dear Jacob & John:

Thank you for your submittal of plan review information to the Oregon Health Authority's Drinking Water Services (DWS). On December 18, 2024, electronic copies of the plans and a Land Use Compatibility Statement were received. On February 26, 2025, our office received a printed copy of the plans for the project. On February 27, 2025, the plan review fee of \$825 was received. The project consists of installing 18-inch C900 pipe at the Gar Swanson Drive road extension. The plans have been reviewed and are approved based on meeting the following condition:

1. All crossings of water and sanitary sewer lines must meet the provisions of [OAR 333-061-0050\(9\)\(c\)](#).

Upon completion of the project, please verify in writing that the construction was completed according to the submitted plans. If substantial changes are made, a set of record (as-built) drawings must be submitted. Until it is verified that the project meets the construction standards in OAR 333-061-0050 and Final Approval is granted for the project, the new facilities are not approved for use.

May 16, 2025

If you have any questions or would like this in an alternate format, please feel free to call me at (541) 966-0900 or email at [william.h.goss@oha.oregon.gov](mailto:william.h.goss@oha.oregon.gov) .

Sincerely,



William Goss, PE  
Regional Engineer

c: Julie Wray, OHA-DWS  
Miff Devin, Port of Morrow (pdf copy only)

