



PUBLIC HEALTH DIVISION  
Drinking Water Services

Kate Brown, Governor

Oregon  
**Health**  
Authority

800 NE Oregon Street, #640  
Portland, OR 97232-2162  
Phone: 971-673-0191  
Fax: 971-673-0694  
[www.healthoregon.org/DWP](http://www.healthoregon.org/DWP)

March 9, 2020

Jenn Minton, PE  
WWSS Commission  
1850 SW 170<sup>th</sup> Ave  
Beaverton, OR 97003

**Re: Raw Water Facility Project (PR#5-2020)  
WWSS Commission (PWS ID#01545)  
Conditional Approval**

Dear Ms. Minton:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the raw water facility project for WWSS Commission. On January 10, 2020, our office received a set of plans, specifications, land use compatibility statement and a plan review fee of \$3,300. Upon review of the scope of the project, DWS determined that a plan review fee of \$825 is appropriate; a refund of \$2,475 has been initiated.

The project includes alteration of the City of Wilsonville's current intake including intake screen replacement, alteration of the existing raw water pump station including six new pumps (four large, two small), 66" raw water pipeline and associated piping and appurtenances.

The plans are approved with the following conditions:

- Water rights information for WWSS Commission's use of the Willamette River must be submitted.
- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- Disinfection of facilities must be accomplished according to the appropriate AWWA Standard.

**Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use.** Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted

plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #5-2020 and can be emailed to me at [Carrie.L.Gentry@state.or.us](mailto:Carrie.L.Gentry@state.or.us) or mailed to:

Attn: Carrie Gentry  
OHA-Oregon Drinking Water Services  
PO Box 14450  
Portland, OR 97293-0450

If you have any questions, please feel free to call me at (971) 673-0191.

Sincerely,

Carrie Gentry, PE  
Regional Engineer  
Drinking Water Services

cc: Nicole Alfafara, OHA/DWS