



PUBLIC HEALTH DIVISION  
Center for Health Protection, Drinking Water Services

Kate Brown, Governor

Oregon  
**Health**  
Authority

800 NE Oregon Street, Suite #640  
Portland, OR 97232-2162  
(971) 673-0459  
(971) 673-0694 – FAX  
<http://healthoregon.org/dwp>

September 11, 2018

Arta Montero  
Portland General Electric  
121 SW Salmon St 3WTCBR03  
Portland, OR 97204

**Re: New Storage Reservoir, Plan Review #121-2018  
Portland General Electric, Beaver Plant, PWS ID # 05246  
Conditional Approval**

Dear Ms. Montero:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the new storage reservoir for Portland General Electric (PGE), Beaver Plant. On September 10, 2018 our office received plans and specifications for the project, prepared by Terri Tovey, P.E., copied on this correspondence, and a plan review fee of \$825. Additionally, we received your emailed clarification on September 10, noting that a flap valve or screen on the end of the overflow pipe and lockable hatch lid will be included, and that the tank will be disinfected and flushed per AWWA Standard C652, which includes receiving coliform absent sample results.

The project includes the construction of a 5,000 gallon welded steel tank for additional storage.


**The plans are approved without conditions and you may proceed with construction.**

**Until final approval has been issued, the reservoir is not approved for use.** Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation should reference Plan Review #121-2018 and can be emailed to me at [james.b.nusrala@state.or.us](mailto:james.b.nusrala@state.or.us), or mailed to:

Attn: James Nusrala  
OHA-Oregon Drinking Water Services  
800 NE Oregon Street, Suite 640  
Portland, OR 97232-2162

If you have any questions or concerns, or would like this in an alternate format, please contact me at (971) 673-0459, or [james.b.nusrala@state.or.us](mailto:james.b.nusrala@state.or.us). Your cooperation is appreciated.

Sincerely,



James Nusrala, P.E.  
Regional Engineer  
Drinking Water Services

cc:

Terri Tovey, P.E. Principal Structural Technologist, Jacobs CH2M, 2020 SW Fourth Ave,  
Suite 300, Portland, OR 97201

Wayne Law, PGE Beaver Generating Station, 80997 Kallunki Road, Clatskanie, OR  
97016

Phil White, PGE Beaver Generating Station, 80997 Kallunki Road, Clatskanie, OR  
97016