



800 NE Oregon Street, Suite #640
Portland OR 97232-2162
Phone 971-673-0462
Fax 971-673-0694
healthoregon.org/dwp
peter.r.farrelly@state.or.us

29 April 2019

Arta Montero
PGE Beaver Generating Station
80997 Kallunki Road
Clatskanie Oregon 97016

Re: New UV Reactor (PR #165-2018)
PGE Beaver Generating Station (WS # 05246)
Final Approval

Ms. Montero,

Thank you for your submittal of supplemental plan review information for the new UV reactor for PGE Beaver Generating Station to the Oregon Health Authority's Drinking Water Services (DWS). DWS received written verification that the project has been completed and that all conditions of the February 2019 conditional approval letter have been met, including verifying automatic shut-off triggers after reactor installation. Earlier, our office received plans, rationale and a \$825 plan review fee.

The project involves adding a full-scale UV reactor, VIQUA Pro24-186, to the existing treatment process.

The project is granted final approval and you may place the facilities into use.

If you have any questions or concerns, please contact me at the information above. Thank you for your cooperation in completing the project.

Sincerely,

Pete Farrelly, P.E.
Regional Engineer
Drinking Water Services

enc: Monthly surface water report