

April 30, 2025

Kyle Climer  
ODOT  
541 Stanton Blvd.  
Ontario, Oregon 97914

**Re: Arsenic POU Treatment Unit, Plan Review #3-2023, ODOT Stanton Blvd. Facility,  
PWS ID# 4106055  
Final Approval**


Dear Kyle:

Thank you for your submittal of documentation to the Oregon Health Authority's Drinking Water Services confirming the project was completed in accordance with the approved plans. The project consisted of installing an APEC ROES-50 reverse osmosis treatment unit treatment system in the State Police office. An arsenic sample collected on February 28, 2024 had a result of "non-detect", which confirmed the new treatment unit is operating effectively. **Final approval is granted for the project.**

The total dissolved solids (TDS) meter must be used to check the new unit's performance and determine when the membrane must be replaced as described in the owner's manual. Note that arsenic samples are required annually from each of the three point-of-use units to confirm they continue to operate effectively.

If you have any questions or would like this in an alternate format, please feel free to call me at (541) 966-0900 or email at [william.h.goss@oha.oregon.gov](mailto:william.h.goss@oha.oregon.gov).

Sincerely,



William Goss, PE  
Regional Engineer

c: Julie Wray, OHA – Drinking Water Services  
Stephen Robertson, ODOT (pdf copy only)  
Teresa Bock, ODOT (pdf copy only)