



February 16, 2024

Tim Hansen, Director
Christian Renewal Center
Via email: tahatrc@gmail.com

**Re: Reservoir (PR#91-2023)
Christian Renewal Center (PWS ID#90494)
Conditional Approval**

Dear Tim:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the reservoir project for Christian Renewal Center. On December 6, 2023, our office received a system description, site plan and photographs. A plan review fee of \$825 was received on January 16, 2024.

The project includes a 3,000-gallon plastic reservoir, installed in 2023. Under OAR 333-061-0060(1)(b), submittals must be prepared by a Professional Engineer registered in Oregon, unless exempted by DWS. An exemption was approved for this submittal. Note that by utilizing this exemption, the water system takes full responsibility for the design of the project.

The plans are approved with the following conditions:

- A fence or other vandal deterrence must be provided for the reservoir.
- The roof access hatch must have curbing around the opening and a lockable watertight cover that overlaps the curbing. I was unable to tell from the photos submitted whether or not this standard has been met.
- A method for draining the water from the reservoir to daylight must be provided. Please provide documentation as to how this standard has been met.
- An explanation for the plastic bag-looking object on the top of the tank must be provided.

Until we receive verification that the conditions have been met and final approval has

been issued, the facility is not approved for use. Documentation demonstrating how the above conditions were met should reference Plan Review #91-2023 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read 'Carrie Gentry', with a stylized flourish at the end.

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Chantal Wikstrom, REHS, OHA/DWS
Greg DeBlase, REHS, Marion County Health Department