

January 7, 2025

Bryan Wood
Applegate Elementary 66
85955 Territorial Road
Eugene, OR 97405

sent by email only


**Re: Corrosion Control System (PR#7-2024)
Applegate Elementary (PWS ID#90894)
Final Approval**

Dear Bryan Wood:

On November 21, 2024, the Oregon Health Authority Drinking Water Services (DWS) received confirmation that the above project was completed according to the plans submitted and conditions set forth in the February 2nd, 2024, conditional approval letter and as-builts information provided by Oregon Water Services on November 21, 2024.

This verification completes the plan review requirements. Final approval for the construction is issued at this time, and the facility is approved for use. With the new corrosion caustic soda control system operational, perform the necessary corrosion control studies and analysis to evaluate the new corrosion control and develop optimum corrosion control and minimum water quality parameters. It is encouraged to utilize the DWS Circuit Rider assistance program for this analysis. The water system will also need to perform two 6-month rounds of lead and copper sampling in the water distribution system. The water system will need to utilize at least 10 sample sites in its distribution system. Coordinate with the direct public water system regulator, Lane County Public Health, for the required lead and copper distribution sampling and for developing minimum water quality standards. If you have any questions, please feel free to call me at 541-231-9077.

Sincerely,

A handwritten signature in black ink, appearing to read "Zach Golik". The signature is fluid and cursive, with the first name "Zach" and last name "Golik" clearly distinguishable.

Zach Golik, PE
Regional Engineer
OHA-Drinking Water Services
email

CC: Sue Yellowtail, Lane County Public Health