



750 SE Emigrant Ave., Suite 150
Pendleton, OR 97801
(541) 276-8006
FAX (541) 276-4778
www.healthoregon.org/dwp

June 15, 2023

Tess Workman Oregon Parks & Recreation Dept. 72214 Marina Lane Joseph, Oregon 97846

Re: New Storage Tanks and Chlorination System, Plan Review #50-2020, OPRD Minam Rec Area - North, PWS ID #4191077 Final Approval

Dear Tess:

Thank you for providing confirmation on May 27, 2023, that a raw water sample tap was installed, showing that the project met OHA construction standards. The project consisted of installing four Flotec pressure tanks to replace the existing redwood tank and installing a new hypochlorination system with a Stenner feed pump. A site visit conducted on May 10, 2023 confirmed the pertinent details of the installation. Final approval is granted for the project.

If you have any questions or would like this in an alternate format, please feel free to email me at william.h.goss@oha.oregon,gov or call me at (541) 966-0900.

Sincerely,

William Goss, P.E. Regional Engineer

William &

c: Julie Wray, OHA–DWS, Portland, OR Patricia Bass, OPRD