



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

2080 Laura St.
Springfield, OR 97477
Mobile Phone: 541-231-9077
Phone Duty: 971-673-0405
Fax: 541-465-2914
www.healthoregon.org/dws

July 12th, 2024

Mark Harshman
Tu-Tu-Tun Lodge/Four Season's Resort
96550 N. Bank Rogue River Road
Gold Beach, OR 97444

Re: **4-Log Disinfection (PR# 54-2024)**
Tu-Tu-Tun Lodge/Four Season's Lodge (PWS ID#91199)
Final Approval

Dear Mark:

On May 1st, 2024, the Oregon Health Authority Drinking Water Services (DWS) received confirmation that the above project was completed according to the submitted information and conditions set forth in the April 18th, 2024, conditional approval letter.


This verification completes the plan review requirements. Final approval is issued at this time, and the facility is approved for use. The Tu-Tu-Tun Lodge and Four Seasons Resort required 4-log disinfection system is approved within the following parameters:

- Maximum flow = 60 gallons-per-minute
- Minimum effective volume = 243 gallons
- Contact time = 4.05 minutes
- Required CT = 6.0 mg-min/L
- **Minimum chlorine residual at entry point = 1.5 mg/L**

If the water system parameters change, the water system will need to provide new 4-log disinfection calculations.

If you have any questions, please feel free to call me at 541-914-7021.

Sincerely,

A handwritten signature in black ink that reads "Zach Golik". The signature is written in a cursive, slightly slanted style.

Zach Golik, PE
Regional Engineer
Drinking Water Services

CC: Julie Wray, DWS Portland
Kent Downs, DWS Springfield