

March 20, 2026

Robert Long, RG, LHG, CWRE
CWM-H2O, LLC
311 B Avenue, Suite P
Lake Oswego, Oregon 97034

**Re: New 3000-Gallon Reservoir, Plan Review #24-2026, Metro Parks - Oxbow,
PWS ID #4191943
Conditional Approval**

Dear Mr. Long:

Thank you for your submittal of plan review information to the Oregon Health Authority's Drinking Water Services (DWS). On February 18, 2026, a letter with details including a set of drawings for the project was received. On February 19, 2026, the plan review fee of \$825 was received. I note that a Land Use Compatibility Statement is not required for this project. The project consists of installing a new 3000-gallon stainless steel reservoir, replacing the media tanks for iron and manganese removal, new booster pumps, and related piping and appurtenances. This review is limited to the new 3000-gallon reservoir, which is approved subject to the following condition:

- The stainless-steel reservoir must be certified to NSF Standard 61 or equivalent. If the selected reservoir does not have this certification, an application for a waiver from the construction standards should be submitted. The waiver application form is online here:
www.healthoregon.org/pwsplanreview

I also have the following comments:

- The new media tanks and booster pumps should be certified to NSF Standard 61 or equivalent.
- I note that installation of the new piping falls under Oregon Building Codes Division's Plumbing Specialty Code. I recommend contacting the [local building code official](#) to determine if a plumbing permit is required for the project.

Upon completion of the project, please verify in writing that the construction was completed according to the submitted plans. Until Final Approval is granted for the project, the new facilities are not approved for use.

If you have any questions or would like this in an alternate format, please feel free to call me at (541) 966-0900 or email at william.h.goss@oha.oregon.gov.

Sincerely,



William Goss, PE
Regional Engineer

c: Julie Wray, OHA-DWS

Cole Hawkey, Oregon Metro (pdf copy only)

Rafael Lopez, Oregon Metro (pdf copy only)

Jane Vail, PE, Wallis Engineering

Jenifer George, REHS, Multnomah County (pdf copy only)